

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50555672

Blatt Sheet
0001

Ihr Zeichen Client Reference
L.T.L.

Unser Zeichen Our Reference
01-SYF-CN22624S 001

Ausstellungsdatum Date of Issue
07.09.2022 (day/mo/yr)

Genehmigungsinhaber License Holder
VIETNAM ELECTRIC CABLE CORPORATION
70-72 Nam Ky Khoi Nghia str.
Nguyen Thai Binh ward,
Dist. 1 Ho Chi Minh city 70000
Vietnam

Fertigungsstätte Manufacturing Plant
VIETNAM ELECTRIC CABLE CORPORATION
70-72 Nam Ky Khoi Nghia str.
Nguyen Thai Binh ward,
Dist. 1 Ho Chi Minh city 70000
Vietnam

Prüfzeichen Test Mark



Type Approved
Safety
Regular Production
Surveillance

www.tuv.com
ID 1111258245

Geprüft nach Tested acc. to
EN 50525-3-41:2011

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Cable (Low voltage Power Cable)

Type Designation: CE/FR-LSHF-450/750V 1X1,5...630mm²

12

Rated Voltage : AC U_o/U 450/750V

Maximum Temperature
at Conductor : 90°C

Mark of Origin : CADIVI

Remark : Category C for IEC 60332-3-24 : 2018
Protocol CWZ for BS 6387:2013
Assessment of fire integrity of large diameter power
cable for BS 8491:2008

12

ANLAGE (Appendix) : 1,0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

http://www.tuv.com/safety E-mail: markcheck@tuv.com
Fax: +49 221 806-3935



Zertifizierungsstelle

Kenny Shi